JRS INDUSTRIAL & POWER SOLUTIONS
1072 KING EDWARD ST., WINNIPEG, MANITOBA, CANADA
Phone: (204) 775-8561 Fax: (204) 786-2491

ISO 9001

CUSTOMER SERVICE TERMINATION ENCLOSURE (With Metering)

CATALOG NUMBER AND DATA SHEET (To be included with all CSTE orders)

DIMENSIONS:
WALL/STRUC. MOUNT: 40"high x 36 1/4"wide x 15 3/4"deep

WEIGHT:
Approx. 250 lbs

400 amp 1Ø Metering
Wall Mount use CSTE331

CSTE 431 - ____ - ____ - ____ - M - WMA

- WMA-Wall Mount Assembly
- M-Metering
- 13-single phase 3-wire
  33-three phase 3-wire
  34-three phase 4-wire
- 1 - 120/240 VOLT
  2 - 120/208 VOLT
  3 - 347/600 VOLT
  5 - 240/480 VOLT
- 4 - 400 AMP
  6 - 600 AMP
  8 - 800 AMP
  10 - 1000 AMP

JOB NUMBER:

SKETCH NUMBER:
SK-

DATE:

DRAWN:

CHECKED:

LINE LUGS (INCOMING)
QUANTITY PER Ø & NEUTRAL

☐ STANDARD PROVISION FOR
(2)-2-HOLE NEMA MAX.
750 MCM COMPRESSION LUGS
(4)- 2-HOLE NEMA MAX. IN
CONTINUOUS BUS SPLITTERS

Qty.	Single	Twin	
____	☐	☐	250 (6 to 250)
____	☐	☐	350 (6 to 350)
____	☐	☐	600 (2 to 600)
____	☐	☐	800 (300 to 800)

LOAD LUGS (OUTGOING)
QUANTITY PER Ø & NEUTRAL

Qty.	Single	Twin	
____	☐	☐	2/0 (14 to 2/0)
____	☐	☐	250 (6 to 250)
____	☐	☐	350 (6 to 350)
____	☐	☐	600 (2 to 600)
____	☐	☐	800 (300 to 800)

GROUND LUGS

Qty.	Single	Twin	
____	☐	☐	2/0 (14 to 2/0)
____	☐	☐	250 (6 to 250)

NOTES:
1) Wall Mounted does not include Remote Meter Cabinet. RMC is required on single phase enclosure. Order RMC on separate line item.

2) Applications with metering, the load bus is suitable for max. 8-350 MCM or 6-600 MCM or 4-800 MCM conductors per Ø and neutral

CSTE431- - - -M-WMA



ELEVATION

SUITABLE FOR UP TO 1000 AMPS

SUITABLE FOR BAR TYPE C.T.'S ONLY



ELEVATION: LESS DOOR



TYPICAL SIDE VIEW

JOB #

SKETCH # SK-

MATERIAL: 12 GA. PAINT GRIP STEEL
NEOPRENE GASKET

FINISH: POWDER COATED ANSI #61 GREY LOW GLOSS

JRS INDUSTRIAL & POWER SOLUTIONS
1072 KING EDWARD ST.
WINNIPEG, MANITOBA
CANADA.

PRODUCT	Customer Service Termination Enclosure CSTE431
DRAWING TITLE	CSTE431 WALL MOUNTED 3Ø 4W C/W METERING
APPROVED BY: JOHN MOLNAR	FORM NUMBER: FN 08 16 RO1
DRAWN BY: FREDDIE DAVID	DATE: MAR 20/202
	SCALE: NTS
	SHEET 2 OF 2