JRS INDUSTRIAL & POWER SOLUTIONS
1072 KING EDWARD ST., WINNIPEG, MANITOBA, CANADA
Phone: (204) 775-8561 Fax: (204) 786-2491

ISO 9001

CUSTOMER SERVICE TERMINATION ENCLOSURE **(with or without metering)**
CATALOG NUMBER AND DATA SHEET (To be included with all CSTE orders)

DIMENSIONS:
60"high x 60"wide x 29"deep PAD MOUNTING

WEIGHT:
Approximately 850 lbs

CSTE 662 - ___ - ___ - ___ - M

- M-Metering
- SP-Splitter (no metering)

- 33-three phase 3-wire (Splitter)
- 34-three phase 4-wire

- 2 - 120/208 VOLT
- 3 - 347/600 VOLT
- 4 - 600 VOLT (Splitter)
- 5 - 277/480 VOLT

- 20 - 2000 AMP (Metering)
- 25 - 2500 AMP
- 30 - 3000 AMP
- 35 - 3500 AMP
- 40 - 4000 AMP
- 120 - 1200 AMP
- 160 - 1600 AMP

JOB NUMBER:

SKETCH NUMBER:
SK-

DATE:

DRAWN:

CHECKED:

☐ Remote Meter Cabinet required.
- Remote Meter Cabinet will be supplied loose.

LINE LUGS (INCOMING)
QUANTITY PER Ø & NEUTRAL

☐ STANDARD PROVISION FOR (4)-2-HOLE NEMA MAX. 750 MCM COMPRESSION LUGS

Qty.	Single	Twin	
___	☐	☐	250 (6 to 250)
___	☐	☐	350 (6 to 350)
___	☐	☐	600 (2 to 600)
___	☐	☐	800 (300 to 800)

LOAD LUGS (OUTGOING)
QUANTITY PER Ø & NEUTRAL

Qty.	Single	Twin	
___	☐	☐	2/0 (14 to 2/0)
___	☐	☐	250 (6 to 250)
___	☐	☐	350 (6 to 350)
___	☐	☐	600 (2 to 600)
___	☐	☐	800 (300 to 800)

GROUND LUGS

Qty.	Single	Twin	
___	☐	☐	2/0 (14 to 2/0)
___	☐	☐	250 (6 to 250)
___	☐	☐	350 (6 to 350)

NOTES:
1) Applications with metering, a Remote Meter Cabinet is required.
2) Applications with metering are Suitable from 2000 AMPS to 4000 AMPS
3) Applications of Splitter with NO metering are Suitable from 2500 AMPS to 4000 AMPS

CSTE662 - X - X - XX - M - PMA



PLAN VIEW



BASE DETAIL

NOTE:

IF REMOTE METER CABINET IS REQUIRED, IT WILL BE SUPPLIED LOOSE.

SUITABLE FROM 2000 AMPS TO 4000 AMPS

SUITABLE FOR BAR TYPE AND WINDOW TYPE C.T.'S

LINE SIDE BUS C/W STUDS FOR (4) - 2-HOLE NEMA MAX. 750 COMPRESSION LUGS PER Ø & N.



ELEVATION



ELEVATION: LESS DOORS

JOB #

SKETCH # SK-

MATERIAL: 12 GA. PAINT GRIP STEEL
-NEOPRENE GASKET

FINISH: POWDER COATED ANSI #61 GREY
LOW GLOSS

JRS INDUSTRIAL & POWER SOLUTIONS
1072 KING EDWARD ST.
WINNIPEG, MANITOBA
CANADA.

APPROVED BY: JOHN MOLNAR

DRAWN BY:

PROJECT: Customer Service Termination Enclosure CSTE662

DRAWING TITLE: CSTE662 W.P. PAD MTG. 3Ø 4W C/W METERING

FORM NUMBER: FN 04 21 R08

DATE: MAR 30/2023